



RISK REMINDER

Above Ground Fuel Tanks

The following are some major guidelines and recommendations:

- Fuel tanks must be kept outside and 30 feet away from your building, and also 20 feet away from the road.
- The contents must be listed and marked flammable.
- The tanks must be double walled, or if they are single walled must be in a containment system.
- The tanks should have some kind of protection around them; bollards, guardrails etc.
- Fire extinguishers must be close by.
- The tanks should have an emergency shut off.



For more information, contact TOIRMA at (888) 562-7861

CLAIM REPORTING HOTLINE (844) 562-2720 | Available 24/7